



The Lowcountry's Hometown

PO Box 700 Moncks Corner, SC 29461 843-719-7900

Lowcountry's Hometown Festival

**Return your application to:
Town of Moncks Corner
Attn: Casey Tharp
118 Carolina Ave.
Moncks Corner, SC 29461
Deadline April 17th**

Business Name: _____ Phone: _____

Contact Person: _____ Email: _____

Address: _____

City: _____ State: _____ Zip: _____

Website: _____

Facebook: _____ Instagram: _____

Moncks Corner Business License # _____

SC Tax Revenue # _____

Please list the items that you will be selling:

List information for SCDHEC certified preparation kitchen:

Business Name: _____ Contact Person: _____

Address: _____

City: _____ State: _____ Zip: _____

Fee enclosed ___ \$75 **Food Vendor** Fee Enclosed ___ \$50 **Vendor**

Please note: Applications will not be considered without the entry fee and vendors cannot participate without a peddler's license obtained through the Town.

**Thank you for your cooperation and participation in the
Moncks Corner Lowcountry's Hometown Festival!**



The Lowcountry's Hometown

PO Box 700 Moncks Corner, SC 29461 843-719-7900

EVENT VENDER FIRE INSPECTION INFORMATION

The Town of Moncks Corner Building & Codes Enforcement will be conducting inspections of all vendors during special events.

Inspections will include the following but are not limited to:

TENTS

- 1) Label affixed to the tent bearing the identification of size and fabric or material
- 2) Tents greater than 10'x10' shall have a fire-retardant certification
- 3) Open flame devices to include gas, charcoal or other cooking devices shall not be permitted
Inside or within 20' of the tent or membrane structure without approval of the Fire Code Official
- 4) A minimum 10A:2B:C extinguisher shall be located adjacent to all cooking areas
- 5) No cooking that produces grease laden vapors shall be within 20' of any membrane structure
- 6) LP gas cylinders shall be located 10' from membrane structures and secured to prevent falling

GENERATORS

- 1) Fuel shall be stored a minimum of 50' from membrane structures
- 2) A minimum 2A:10B:C extinguisher shall be located at the generator
- 3) Generators shall be a minimum of 20' from membrane structures

FOOD TRUCKS

- 1) All food trucks shall comply with and be inspected to 2018 IFC 319 Mobile Food Preparation Vehicles

All violations will be noted, and time will be given for corrections to be made. If an adequate level of safety is not achieved the vendor may be asked to cease operations.

Feel free to contact me with any questions or concerns.

Thank you for your assistance in creating a fun and safe event,

Chad A. Kelly, CBO, CFM
Chief, Building & Codes Enforcement
Town of Moncks Corner
Email: chad.kelly@monckscornersc.gov
Office: 843-719-7924
Cell: 843-499-0161